

THE BANK OF MYSORE, LIMITED, BANGALORE.

Statement of the affairs of the Bank of Mysore, Limited, for the week ending 16th February 1939, published under Article 141 of the Articles of Association.

LIABILITIES			ASSETS		
		Rs.			Rs.
To Capital Receipts	20,00,000	By Cash in hand and at Bankers	14,97,449
„ Reserve Fund	26,50,000	„ Loans and Cash Credit Accounts	1,89,29,143
„ Public and other Deposits	2,65,53,179	„ Bills discounted and purchased	9,73,335
„ Sundries	1,58,350	„ Investments	90,98,323
			„ Balance at Agencies
			„ Dead Stock	7,87,189
			„ Sundries	76,090
Total		3,13,61,529			
(Annas and pies omitted.)				Rs.	3,13,61,529

BANGALORE,
Dated 20th February 1939.

F. L. PERADON,
Manager.

GOVERNMENT OF MYSORE, STORES PURCHASE COMMITTEE, BANGALORE.

No. S. P. O. 21638-75, dated 14th February 1939.

To

The Firms dealing in Oil Engine Pumping Sets.

Enquiry No. 3299.

OIL ENGINE PUMPING SET FOR HANGALA WATER SUPPLY.

GENTLEMEN,

Please be good enough to intimate your best prices for delivery f.o.r., Gundlupet Out Agency, Mysore State Railway, and the earliest time of delivery for an Oil Engine Pumping Set of the following specification :—

Specifications for a Power Driven Pumping Unit required.

Pump.—The pump is to be either of the plunger or centrifugal type and be capable of lifting 1,000 gallons an hour against a total head of 165' from all causes.

The supply is to be drawn from a well 32' deep and the delivery head is 133'. Centrifugal pumps of the injector type that can work with a suction lift of 32' will be preferred and may be quoted for alternatively.

The pump should be of the best type and should be supplied with a foot-valve of ample size besides a delivery, a non-return valve and a pressure gauge. The accessories should be quoted for separately.

Engine.—This pump will have to be driven by an engine that can develop enough power at an altitude of 2,500' and at a maximum temperature of 100°F.

The engine should run on light diesel oil ordinarily available in the market.

The engine shaft should, if necessary, be extended on one side to take in the driving pulley.

The unit should be supplied with necessary pulleys and a complete set of spares.

The specifications should indicate the fuel consumption on full and half loads, and a test certificate should accompany the supply.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellation of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Oil Engine Pumping Set for Hangala Water Supply" with the above Enquiry Number.

This enquiry will be closed on the 16th March 1939.